



DRAWING LEGEND:

Tracking:

- Denotes Fire Appliance Sweep Path.
- Fire Appliance Wheel Path.
- Fire Appliance Chassis Path.

Fire Access & Facilities:

- Indicative Horizontal Dry Riser Installation with Underground Feed.
- Indicative Below Ground Hydrant Valve.
- Indicative Vertical Dry Riser.
- Hose Travel Distance.
- Edward and Pellow House Outline.

*All Plots to Have Automatic Fire Suppression System.

Fire Strategy Summary:

Step 1 - The Fire Tender arrives at the entrance to the courtyard being served and a clear and unobstructed view of the horizontal dry riser. A firefighter connects the tender to the Riser (max 45).

Step 2 - Another Firefighter carries a hose to the front door or the appropriate dwelling and connects the hose to the nearest below ground hydrant (yellow Plate), located at the front of each dwelling.

Step 3 - The Firefighters can then proceed with pumped water.

*For All Plots except Pellow House and Edward House. For the detailed strategy of these two blocks, please refer to the Fire Safety Strategy Report (21/11/2024) produced by Rockland Safety Services Ltd.

Bartholomew Street subject to improvement works to enable two-way traffic, in part, to access the site.

NOTES

- Contractors must check all dimensions on site. Only figured dimensions are to be worked from. Discrepancies must be reported to the Architect or Engineer before proceeding. © This drawing is copyright.
- Reproduced from OS Sitemap @ by permission of Ordnance Survey on behalf of The Controller of Her Majesty's Stationary Office. © Crown copyright 2008. All rights reserved. Licence number 100007126.
- Direct scaling off the drawing is permissible for planning purposes only.

Proposed highway improvements to facilitate access into the site.
In line the transport assessment -
Document Reference:
18916100-WAT-HGN-ZZ-DR-C-950122-P01

LOCHAILORT

Woods Hardwick

Architecture | Engineering | Planning | Surveying

BEDFORD : HEAD OFFICE
15-17 Goldington Road
Bedford MK40 3NH
T: +44 (0) 1234 268862
ONLINE: mail@woodshardwick.com | woodshardwick.com

BIRMINGHAM
Fort Dunlop, Fort Parkway
Birmingham B24 9FE
T: +44 (0) 121 6297784

PLEASE CONSIDER THE ENVIRONMENT BEFORE PRINTING THIS DRAWING